

RESIDENTIAL ELECTRICAL LOAD CALCULATIONS

Lighting Loads

220-12 Living area sq. ft. _____ x 3 volt amperes per sq. ft. = _____ VA
 220.52A Two small appliance circuits (required) x 1500VA = 3000 VA
 220.52B Laundry circuit(s) _____ x 1500VA = _____ VA
 220.52A Additional small appliance circuit(s) _____ x 1500VA = _____ VA
 Lighting Load Sub-total = _____ VA

220.42 First 3000 volt-amperes of lighting loads @ 100% = 3000 VA
 From 3001 to 120000 VA @ _____ 35% = _____ VA
 Remainder over 120000 VA @ _____ 25% = _____ VA
 Lighting Load Total Volt-Amperes = _____ VA (A)

220.55 Household Cooking Appliances
 (Use table 220-55) Number of Appliances _____ = _____ VA
 Cooking Units Total Volt-Amperes = _____ (B)

220-53 Appliance Loads (nameplates)

Microwave	1500 VA x _____	= _____	VA
Compactor	1200 VA x _____	= _____	VA
Dishwasher	1200 VA x _____	= _____	VA
Disposal	600 VA x _____	= _____	VA
Central Vacuum	1800 VA x _____	= _____	VA
_____	_____ VA x _____	= _____	VA
_____	_____ VA x _____	= _____	VA
Appliance Sub-Total		= _____	VA

Appliance Sub-Total _____ x _____ % = _____ Volt-Amperes (C)
 (Less than 4 units x 100%, 4 or more units x 75%)

220-54 Dryer-5000 VA or nameplate (whichever is greater) = _____ VA (D)
 422-10A Water Heater (nameplate) x 125% = _____ VA (E)
 220-14 Pool/Spa motor loads: Sum all plus 25% of largest = _____ VA (F)
 Add totals of (A) (B) (C) (D) (E) (F) Total Volt-Amperes = _____
 Total Volt-Amperes/240 = _____ Amps (G)

220-14C Largest cooler, A/C or heating load
 _____ KVA _____ Volts x 125% = _____ Amps (H)

Total Service (G) + (H) = _____ AMPS



ELECTRICAL LOAD CALCULATIONS

**HELP FOR THE HOMEOWNER
FOUNTAIN VALLEY BUILDING & SAFETY**

Darik Doggett, CBO 2/16/16
Building Official Date

Date: 4/5/11

Sheet 1 of 1

E-2